

SUFFOLK COUNTY SEWER DISTRICT NO. 3 - SOUTHWEST
BERGEN POINT OUTFALL EMERGENCY RESPONSE PLAN
PRE-STRESSED CONCRETE CYLINDER PIPE AND PRE-CAST CONCRETE
MANHOLE PROCUREMENT

ADDENDUM No. 2

TO: Prospective Bidders
DATE: September 30, 2011

This addendum shall be part of the Contract Documents for the above referenced project.

SPECIFICATION CHANGES:

Bid Form

On page BF-6; Item Number 6, delete “36-in” and replace with “42-in”.

DIVISION 2

Section 02605 – Precast Concrete Manholes

On page 02605-3; Part 1.06 B, first line; delete “36-in” and replace with “42-in”.

On page 02605-3; Part 1.06 C, first line; delete “14-in” and replace with “20-in”.

On page 02605-3; Part 1.06 C, first line; delete “4 inches” and replace with “5 inches”.