

NYS CHLORINATION REQUIREMENTS for SWIMMING POOLS and SPAS

pH RANGE

FREE AVAILABLE CHLORINE RESIDUAL

POOLS

≤ 7.8	0.6 - 5.0 ppm
> 7.8 - 8.2	1.5 - 5.0 ppm

SPAS

7.2 - 7.8	1.5 - 5.0 ppm
-----------	---------------

(required pH range)